GOVERNMENT OF MYSORE STORES PURCHASE COMMITTEE, BANGALORE.

No. S. P. C. 22484-22500, *dated 28th June* 1935.

To

The Firms dealing in Electrical materials.

Enquiry No. 1413.

DISCONNECTING SWITCHES AND FUSIBLE CUT-OUTS.

GENTLEMEN,

I write to request you to quote your best prices and earliest time of delivery for the following materials which should comply with the specifications and details attached herewith :—

Item (1) 6 Sets of Horn Gap Out-door Type Disconnecting switches each set consisting of 3 single phase single throw, 78 kilo-volts, 200 amperes, horn-gap disconnecting switches mounted on galvanized channel iron bases sand gang operated by means of levers. For further details please refer to attached specifications.

,, (2) One set do do but for 13,200-volts service.

,, (3) 6 sets of Out-door Expulsion type Fusible Cut-outs, each switch consisting of 3 single pole, 78,000-volts, 5-amperes, expulsion type fusible cut-outs mounted on galvanised iron channels and provided with operating eye.

The rupturing capacity of the fuses should be specified by the tenderers and should not be less than 1,000-amperes (RMS) at 78,000-volts.

,, (4) 6 Sets do do but of 10-amperes capacity each.

,, (5) 100 spare Fuses of 5-amperes capacity for the above.

,, (6) 100 spare Fuses of 10-amperes capacity for the above.

,, (7) 2 sets of Fusible Cut-outs, each set consisting of 3 single pole out-door type expulsion fusible cut-outs of 30 amperes capacity for 13,200-volts service. The cut-outs are to be mounted on galvanized iron channels and provided with operating eye.

The rupturing capacity of the cut-outs should be specified by the tenderers and should not be less than 5,000 amperes (RMS) at 13,200-volts.

,, (8) 50 spare fuses for the above.

Descriptive drawings should accompany the tenders.

The prices to be quoted should be for delivery c. i. f., Madras.

This enquiry will close on the 16th September 1935.

Specifications for the materials required for Electrification of Towns enroute to Bhadravati.

A. Horn Gap disconnecting Switches.

These switches should consist of 3 single phase, single throw, horn gap disconnecting switches mounted on channel bases and capable of gang operation. They are intended to be installed out-doors and to be connected between 78 KV., 3 phase, overhead transmission line and the high tension side of step-down transformers without oil circuit breakers, but in conjunction with separate expulsion type fusible cut-outs as described below :—

The horn gap disconnecting switches are meant to isolate transformers from the supply line either for interrupting service or for replacing the fuse element of the cut-outs and as such should be capable of interrupting exciting currents of 3 phase transformer banks of 1,000 KVA capacity and in an emergency also the load currents.

The contacts and hinges should be of sturdy construction and should be of the self-aligning high pressure type and the switches should be suitable for horizontal up-right mounting on pole tops or out-door station structures. Ample phase-spacing and break distances are to be provided to interrupt successfully the arcs generally established in service.

The insulators supporting these switches should be of the cemented cap and pin type assembled into a stack and be interchangeable with each other. The leakage distance, the dry and wet flash-over values and the mechanical strength of each of these insulators forming the stacks should be clearly specified by the tenderer.

The horn gap disconnecting switches for 13,200-volts service should be similar to the 78 KV ones except as regards the rating and are intended for 3 phase transformer banks of 600 KVA capacity.

B. Fusible Cut-outs.

(1) 78,000-*volts service* :—The fusible cut-outs must be of the expulsion type and should not warp or deteriorate due to out-door weather conditions. The fuses should be provided with operating eye so that they may be opened and closed as disconnects if necessary.

The fusible cut-outs should be mounted on cemented cap and pin type insulators on galvanized channel iron bases suitable for vertical mounting. The rupturing capacity of the fuses at 78,000-volts should not be less than 1,000-amperes (R.M.S.). The channel iron bases should be provided with grounding lugs.

The mechanical strength, leakage distance, dry and wet flash-over values, etc., of the insulators supporting the cut-outs should be clearly specified by the tenderers.

(2) 13,200-*volts service*:—The cut-outs should conform to specifications mentioned under (1) with the exception that their rupturing capacity at 13,200-volts should not be less than 5,000 amperes (R.M.S.).

No. S. P. C. 22771-80, *dated 28th June* 1935.

To

The Firms dealing in Sanitary Fittings.

Enquiry No. 1417.

SANITARY FITTINGS FOR THE CHILDREN'S WARD OF THE VANI VILAS HOSPITAL, BANGALORE.

DEAR SIR/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the form printed overleaf.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions:—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "quotations for Sanitary Fittings" with the above enquiry Number.

This enquiry will be closed on the 18th July 1935.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
			Bangalore.	
1	Shanks No. 6551 Nisa Washdown Closet comprising adaptus India Rubber joint with Duro earthenware lowdown cistern No. 5551 complete set	2		
2	White porcelain Hindustani Closet white strop 3 gallon C. I. flushing cistern (Shanks reliable) with chain and pull telescope flush pipe and one pair of marble foot rests complete set	4		
3	M. 6564 Shanks straight front Lavatory Basin in lava complete set 25″×19″	3		
4	Glass shelf with N. P. Brackets 24″×5″ ..	3		
5	Bed pan Sink—M. 5870 comprising Shanks M. 6259 bed pan sink on pedestal in white glazed Victorian fireclay transformed in pedestal M. 6273 ½″ gun metal smooth top combined supply fittings for cold water only with screw down cross heads and with copper connecting pipe to bed pan and urine bottles jets in 5896 3-gallon cistern and cover in C. I. glass enamelled inside and painted outside M. 6693 brass valveless syphon new Rotanda fittings M. 4941 Bull cock and M. 4051 painted C.I. brackets for screwing to wall M. 4181 gun metal rod pull and guide M. 6255 ½ gld. steel flush pipe and clip fittings polished ..	3		

N.B.—Quotations for delivery immediately from stock only will be considered.

No. S. P. C. 22748-70, *dated* 28*th June*—2*nd July* 1935.

To

The Firms dealing in Water Meters.

Enquiry No. 1418.

FULL BORE WATER METERS.

DEAR SIR/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the form printed below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions:—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for 4" Water Meters" with the above Enquiry Number.

This enquiry will be closed on the 15th July 1935.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
	Water Meters, full bore, helical to be put on 4" mains capable of registering flows varying between 20,000 and 50,000 gallons per day as per specification noted below	Two	Bangalore.	

Brief Specification of a 4" Water Meter.

An inferential, dry dial, circular registering Cold Water Meter to be fitted on a 4" C. I. pipe line conveying filtered water having a residual chlorine content of 1/10 part per million, fitted with a separate, easily detachable dust box and strainer of special non-corrosive material. The meter is to be provided with locking as well as sealing arrangements with lead seals and wire.

The capacity of the meter should be up to 10 million gallons and it should register correct to an accuracy of plus minus 2 per cent for all rates of flow between 500 and 8,000 gallons per hour.

A set of tools for opening out and refitting the several parts of the meter is also to be furnished with the meter. Certificate of test and test characteristics should accompany.

No. S. P. C. 36-65, *dated* 2*nd July* 1935.

To

The furniture contractors at Bangalore.

Enquiry No. 1426.

FURNITURE REQUIRED FOR THE VANI VILAS HOSPITAL, BANGALORE CITY.

DEAR SIR/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the form printed overleaf

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions:—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for furniture required for the Vani Vilas Hospital, Bangalore City" with the above Enquiry Number.

This enquiry will be closed on the 17th July 1935.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
1	Meat safes, teakwood, size 4′×3′×15″, with wire gauge	3		
2	Soiled linen boxes, teakwood, 3′×2′ (half the portion with rattan on 4 sides)	4		
3	Lockers, teakwood, 27″×17″×17″	120		
4	Table, 5′—4″×3′—6″×2′—8″ with 4 drawers and turned legs 3″ thick (for the Medical Officer)	1		
5	Chair for the Medical Officer	1		
6	Carrying chairs, hospital pattern	3		
7	Baby bath table, teakwood, 3′×2′, with one shelf on top	1		
8	Ladies' easy chairs, hospital pattern	6		
9	Large round dressing bins	15		
10	Chairs, hospital	6		
11	Do nurses' quarters	4		
12	Tables, teakwood, standard size	2		
13	Do dressing	4		

N.B.—(1) The articles should be made of well seasoned best Mysore teak, free from defects.

(2) The articles called for against items 4, 5 and 13 should, in every respect, be similar to those in use at the Victoria Hospital.

(3) The remaining items should be similar to those in use in the hospitals.

(4) Quotations should be furnished subject to the above conditions. Applications for enhancement of prices after contracts are let due to whatsoever causes will not be considered.

Yours faithfully,
V. VEDAVYASACHARYA,
Secretary,
Stores Purchase Committee.

No. S. P. C. 22927-28, *dated 29th June* 1935.

NOTICE.

Enquiry No. 1403.

AUTOMATIC TELEPHONE EQUIPMENT.

The Stores Purchase Committee are calling for tenders for the supply and erection of an Automatic Telephone equipment for use in Bangalore City and for shifting the present equipment to Mysore, and installing the same there. Priced tender forms giving full details regarding the enquiry will be furnished on application to the undersigned.

The price fixed for one set of tender forms is Rs. 5. Cheques or postage stamps will not be received towards the cost of the tender forms.

The last date for receipt of tenders is 15th September 1935.

No. S. P. C. 22838, *dated 29th June* 1935.

NOTICE.

Enquiry No. 1408.

SUPPLY OF LUBRICATING OILS REQUIRED FOR THE MYSORE RAILWAYS DURING 1935-36.

Sealed tenders will be received by the Secretary, Stores Purchase Committee, for the supply of mineral and lubricating oils, grease etc., required for the Mysore Railways during the year 1935-36 up to 5 P.M. on 1st August 1935.

Intending tenderers may, on application to the Secretary, Stores Purchase Committee, obtain the requisite tender forms on which tenders should be submitted. Applications should be accompanied by a cash remittance of Rs. 3 which is the price fixed for a set of forms and which is not refundable.

Cheques and postage stamps will not be accepted towards the cost of forms nor will the forms be sent by V. P. P.

No. S. P. C. 22906-15, *dated 1st July* 1935.

NOTICE.

Enquiry No. 1421.

Sealed tenders will be received by the undersigned for 50 tons of Shell Lime required for Water Purification purposes.

Tenders submitted in response to this notice shall be subject to the following conditions :—

(*a*) Shell Lime offered should contain 75 per cent of soluble lime. The material shall be required to be packed in gunny bags of 1 cwt. each and delivered f. o. r., Bangalore City.

(*b*) The prices quoted should be firm for a period of two weeks from the date of receipt of tenders.

(*c*) The whole quantity shall be required to be delivered within 3/4 weeks from the date of order.

(*d*) Samples of material offered should be furnished with the tender in duplicate, accompanied by a test fee of Rs. 15. The acceptance of the tender will depend on the result of test.

(*e*) The material to be supplied should strictly conform to the analysis as ascertained on tests conducted on the sample submitted by the tenderer and accepted by the Committee. Should it be found necessary to verify if the supply conforms to the approved sample, check tests will be arranged by the Committee on samples drawn from the supplies. The cost of such check tests, *viz.*, at Rs. 15 per sample should also be borne by the contractors.

(*f*) Failure to make the supply in accordance with the approved sample and in time, will entail cancellation of the contract and, purchase being made from other sources at the expense of the contractors. Extra cost incurred on such purchases will be recovered from the defaulting contractors. The Stores Purchase Committee in such an event reserve the right to levy a penalty of 3 per cent of the value of the order as and by way of liquidated damages.

Tenders should be submitted in sealed covers, superscribed "Tender for Shell Lime" and delivered at the Office of the Secretary, Stores Purchase Committee, on or before the 15th July 1935.

By Order,
V. VEDAVYASACHARYA,
Secretary,
Stores Purchase Committee.